



ELEVATION



ENLARGEMENT 1



ENLARGEMENT 2

# DETAIL

CABLE RACKS AND RACK ARMS  
SCALE: N/A



## BILL OF MATERIAL

ITEM NUMBER	CATALOG NUMBER	DESCRIPTION	QUANTITY REQUIRED
1	FSRM-12	1/2"-13 DROP-IN ANCHOR MATERIAL: 303 STAINLESS STEEL	5
2	FFW316-18-40	FLAT WASHER ID=.562, OD=1.250, THK=.078 MATERIAL: 316 STAINLESS STEEL	5
3	FHC316-16-044	1/2"-13 x 1-3/8" LG. HEX HEAD CAP SCREW MATERIAL: 316 STAINLESS STEEL	5
4	CR36	CR36 STANCHION MATERIAL: 50% GLASS REINFORCED NYLON	1
5	RA08	RA08 ARM (8" LONG) MATERIAL: 50% GLASS REINFORCED NYLON	1
6	RA14	RA14 ARM (14" LONG) MATERIAL: 50% GLASS REINFORCED NYLON	1
7	RA20	RA20 ARM (20" LONG) MATERIAL: 50% GLASS REINFORCED NYLON	1
NOT SHOWN	FRT-112	SETTING TOOL (USED TO INSTALL CATALOG NO. FSRM-12 DROP-IN ANCHOR)	AS REQ'D

## REVISIONS

NO.	DATE	BY	DESCRIPTION
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS

PROJECT MANAGER:

PROJECT ENGINEER:

DESIGN ENGINEER:

DRAFTER:

SCALE:  
AS NOTED

DATE:

CHECKED/APPROVED BY:



SEA-TAC INTERNATIONAL AIRPORT

PROJECT: F&I STANDARD DETAILS

SHEET TITLE: **SWITCH VAULT DETAILS**  
**MISCELLANEOUS SWITCH VAULT DETAILS**

WORK PROJECT NO.

CONSULTANT'S NO.

PORT OF SEATTLE NO.

260543

04